Product fiche concerning the COMMISSION DELEGATED REGULATIONS

(EU)No 811/2013 of 18 February 2013

(EU)No 813/2013 of 2 August 2013

Air Source Heat Pumps

Space Heating Test Standard: EN14825

DHW Test Standard: EN16147

Grant Engineering (Ireland) ULC Barrack Street, Crinkle, Birr, Co. Offaly, R42 D788, Ireland.

t: +353 (0)57 91 20089 f: +353 (0)57 91 21060 e: info@grantengineering.ie w: www.grantengineering.ie



| Model | Outdoor unit: | Aerona ³ HPID10R32 | | |
|------------------------------------|---------------|-------------------------------|--|--|
| | Indoor unit: | None | | |
| Air to Water Heat Pump | | Yes | | |
| Brine to Water Heat Pump | | No | | |
| Low Temperature Heat Pump | | No | | |
| Equipped with Supplementary Heater | | No | | |
| Heat Pump Combination Heater | | Yes | | |
| Parameters shall be declared for | Medium Temper | rature Applications (55°C) | | |
| Parameters shall be declared for | Average | Average Climate Conditions | | |

| Item | Symbol | Value | Unit | Item | Symbol | Value | Unit |
|---|-----------------|-------|-------|---|-------------------------|-------------|--------|
| Rated Heat Output (*) | Prated | 8.7 | kW | Seasonal space heating energy efficiency | ηs | 139 | % |
| Declared capacity for heating for pa | | oor | | Declared coefficient of performance | or primary energ | y ratio for | |
| Temperature 20°C and outdoor tem | perature Tj | | | part load at indoor temperature 20°C | and outdoor tem | perature Tj | |
| $Tj = -7^{\circ}C$ | Pdh | 8.16 | kW | $Tj = -7^{\circ}C$ | COPd | 2.29 | - |
| Degradation co-efficient (**) | Cdh | 0.99 | - | | | | |
| $Tj = +2^{\circ}C$ | Pdh | 5.07 | kW | $Tj = +2^{\circ}C$ | COPd | 3.53 | - |
| Degradation co-efficient (**) | Cdh | 0.99 | - | | | | |
| $Tj = +7^{\circ}C$ | Pdh | 3.40 | kW | $Tj = +7^{\circ}C$ | COPd | 5.41 | - |
| Degradation co-efficient (**) | Cdh | 0.98 | - | - | | | |
| $T_j = +12^{\circ}C$ | Pdh | 3.95 | kW | $Tj = +12^{\circ}C$ | COPd | 8.45 | - |
| Degradation co-efficient (**) | Cdh | 0.99 | - | | | | |
| $T_j = bivalent temperature$ | Pdh | 8.70 | kW | Tj = bivalent temperature | COPd | 2.19 | - |
| Tj = operation limit | Pdh | 8.01 | kW | $T_j = operation limit temperature$ | COPd | 2.01 | - |
| temperature $T_j = -15^{\circ}C$ (if TOL < -20^{\circ}C) | Pdh | | kW | Tj = -15°C (if TOL < -20°C) | COPd | _ | |
| Bivalent temperature -20 C | T an Tbiv | -9 | °C | Operation limit temperature | TOL | -10 | °C |
| Bivalent temperature | 1010 | -9 | C | · · | TOL | -10 | C |
| | | | | Heating water operating limit temperature | WTOL | 60 | °C |
| Power consumption in modes other | than active m | ode | | Supplementary Heater | | | |
| Off Mode | POFF | 0.10 | kW | Rate heat output | P _{sup} | 0 | kW |
| Thermostat-off mode | P _{TO} | 0.04 | kW | 1 | | | |
| Standby mode | P _{SB} | 0.10 | kW | Type of energy input | | | |
| Crankcase heater mode | Рск | 0.00 | kW | | | | |
| Other items | | | | | | | |
| Capacity control | Variable | | | Rated airflow rate, outdoors | - | 2664 | m³/h |
| Sound power level indoors/outdoors | L_{WA} | 43/64 | dBA | | | 1 | 1 |
| Annual Energy consumption | Q_{HE} | 5064 | kWh | | | | |
| For heat pump combination heater | | | | Water heating energy efficiency | ηwh | 99.6 | % |
| Declared load profile | | L | | Reference Hot Water Temperature | <i>θ'</i> _{WH} | 51.60 | °C |
| Daily electricity consumption | Qelec | 4.85 | kWh | Actual Volume of cylinder under test | | 206.8 | Litres |
| Annual electricity consumption | AEC | 1770 | kWh/a | Standby Cylinder Heat Loss | | 1.76 | kWh |

Contact Details:

Grant Engineering (Ireland) ULC, Barrack Street, Crinkle, Birr, Co. Offaly, R42 D788, Ireland.

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



| Model | Outdoor unit: | Aerona ³ HPID10R32 | | |
|------------------------------------|---------------|-------------------------------|--|--|
| | Indoor unit: | None | | |
| Air to Water Heat Pump | | Yes | | |
| Brine to Water Heat Pump | | No | | |
| Low Temperature Heat Pump | | No | | |
| Equipped with Supplementary Heater | | No | | |
| Heat Pump Combination Heater | | Yes | | |
| Parameters shall be declared for | Low Temper | rature Applications (35°C) | | |
| Parameters shall be declared for | Average | Average Climate Conditions | | |

| Item | Symbol | Value | Unit | Item | Symbol | Value | Unit |
|---|---------------|-------|------|---|------------------|-------------|------|
| Rated Heat Output (*) | Prated | 9.2 | kW | Seasonal space heating energy efficiency | ηs | 209 | % |
| Declared capacity for heating for pa | | oor | | Declared coefficient of performance | | | |
| Temperature 20°C and outdoor tem | perature Tj | | | part load at indoor temperature 20°C | and outdoor temp | perature Tj | |
| $Tj = -7^{\circ}C$ | Pdh | 9.03 | kW | $Tj = -7^{\circ}C$ | COPd | 3.30 | - |
| Degradation co-efficient (**) | Cdh | 0.99 | - | | | | |
| $Tj = +2^{\circ}C$ | Pdh | 5.29 | kW | $Tj = +2^{\circ}C$ | COPd | 5.96 | - |
| Degradation co-efficient (**) | Cdh | 0.99 | - | | | | • |
| $Tj = +7^{\circ}C$ | Pdh | 3.40 | kW | $Tj = +7^{\circ}C$ | COPd | 7.80 | - |
| Degradation co-efficient (**) | Cdh | 0.98 | - | | | | |
| $Tj = +12^{\circ}C$ | Pdh | 3.70 | kW | $Tj = +12^{\circ}C$ | COPd | 9.20 | - |
| Degradation co-efficient (**) | Cdh | 0.99 | - | | | | |
| Tj = bivalent temperature | Pdh | 8.86 | kW | Tj = bivalent temperature | COPd | 3.10 | - |
| Tj = operation limit temperature | Pdh | 8.86 | kW | Tj = operation limit temperature | COPd | 3.10 | - |
| $T_j = -15^{\circ}C$ (if TOL < $-20^{\circ}C$) | Pdh | - | kW | $T_i = -15^{\circ}C$ (if TOL < $-20^{\circ}C$) | COPd | - | |
| Bivalent temperature | Tbiv | -10 | °C | Operation limit temperature | TOL | -10 | °C |
| • | | | | Heating water operating limit temperature | WTOL | 60 | °C |
| Power consumption in modes other | than active m | ode | | Supplementary Heater | | | |
| Off Mode | Poff | 0.10 | kW | Rate heat output | Psup | 0.00 | kW |
| Thermostat-off mode | P_{TO} | 0.04 | kW | 1 | | | |
| Standby mode | PSB | 0.10 | kW | Type of energy input | | | |
| Crankcase heater mode | РСК | 0.00 | kW | | | | |
| Other items | | | | | | | |
| Capacity control | Variable | | | Rated airflow rate, outdoors | - | 2664 | m³/h |
| Sound power level indoors/outdoors | $L_{W\!A}$ | 43/64 | dBA | | | | |
| Annual Energy consumption | Q_{HE} | 3592 | kWh | | | | |
| For heat pump combination heater | | | | Water heating energy efficiency | η_{wh} | | % |
| Declared load profile | | NA | | | | | |
| Daily electricity consumption | Qelec | | kW/h |] | | | |
| Annual electricity consumption | AEC | | kW/h | | | | |

Contact Details:

Grant Engineering (Ireland) ULC, Barrack Street, Crinkle, Birr, Co. Offaly, R42 D788, Ireland.

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj). (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



End of Life Information – Air Source Heat Pumps

General

Grant air source heat pumps incorporate components manufactured from a variety of different materials. However, most of these materials cannot be recycled as they are contaminated by the refrigerant and oil used in the heat pump.

Disassembly

This product may only be disassembled by a suitably qualified (F-gas) refrigeration engineer. Under no circumstances should the refrigerant be released into the atmosphere.

Recycling

In order for the heat pump to be recycled or disposed of it must be taken to a suitably licensed waste facility. You will need to contact a qualified refrigeration engineer to do this for you.

Disposal

The refrigerant will be removed and returned to the refrigerant manufacturer for recycling or disposal.

The complete heat pump unit, including the compressor and the oil contained within it, must be disposed of at a licensed waste facility, as it remains contaminated by the refrigerant.

Authorized by:

Peter Dancy

11-05-2020

Grant heat pump fiche. SD002 11/05/2020 V1.5

